

VALVE REGULATED LEAD ACID BATTERIES WARRANTY POLICY

SG SERIES

ONE YEAR GUARANTEE

Daejin Battery Co., Ltd. guarantees to the original end user that SG Series with Premium GEL technology will be free of defects in Material and workmanship for 12 months from date of shipment. Daejin Battery Co.Ltd. must be notified immediately upon suspicion of any possible defects and be given the authority to inspect any questionable sites and/or receive complete report on the incident. If Daejin Battery Co., Ltd. determines the batteries to be defective due to faulty material or workmanship, it will repair or replace them at its option, without charge, FOB port of original loading.

GENERAL OPERATING & WARRANTY CONDITIONS

- 1. Charging voltage 2.25-2.35 VPC at 25 deg.C. The batteries are assumed to be used in cycling service. If used with solar panels as chargers, there must be a high quality charge controller between the solar panels and batteries.
- 2. Temperature:
 - A. Average annual ambient temperature shall not exceed 77 deg. F/25 deg. C.
 - B. Cell temperature shall not exceed 92 deg. F/33 deg. C. for more than 30 days per year.
- 3. The vent caps must not be tampered with or removed.
- 4. The batteries must not be contaminated by any foreign matter.
- 5. This warranty does not apply to broken containers, covers or battery terminals which have been frozen or damaged due to neglect or abuse such as fire, flooding, explosives or any acts of nature.
- 6. Registration, installation and periodic inspection reports regarding temperature and conditions of use are to be maintained by the end user and made available to Newmax Battery on request to support any warranty adjustment claim.
- 7. All batteries should be recharged immediately following a discharge.
- 8. Batteries shall be boost charged every 3-6 months, while in storage, prior to final installation.
- 9. No battery will be covered under warranty in the event of improper installation and maintenance such as overcharging, undercharging, charging or installing in reverse polarity.
- 10. All maintenance functions (handling, storage and installation) must be performed in accordance with Newmax battery's Operation Manual

Note: Newmax batteries are rated to supply at least 95% of capacity at C/20 upon shipment. These batteries will reach 100% capacity after approximately 25 cycles. The user is responsible for the shipping costs of all warranty replacements.